



1/4" x 1 3/8" SLEEVE ANCHOR  
@ 24" O.C. [610mm]  
9360  
1/4-20 x 1/2" FHMS/SS  
100D @ 24" O.C. [610mm]  
9552

**IMPORTANT LIFE SAFETY PRODUCT NOTE**  
PF-2018F-SC-4-2 (OPTIONAL)  
TO ACHIEVE RATING, 2-HOUR FIRE BARRIER  
MUST BE INSTALLED IN 2-HOUR RATED SLAB,  
MINIMUM 4-1/2" JT. FACE. BARRIERS MUST BE  
INSTALLED IN STRICT ACCORDANCE WITH  
TYPICAL FLOOR FIRE BARRIER INSTALLATION  
INSTRUCTIONS PROVIDED IN THIS SUBMITTAL.

\* CONTACT FACTORY FOR OTHER STYLES OF FIRE BARRIER

**IMPORTANT LIFE SAFETY NOTE**  
4-1/2" MINIMUM FACE OF SLAB (AS SHOWN)  
REQUIRED FOR OPTIONAL FIRE RATING TO  
BE AVAILABLE IN ACCORDANCE TO IBC  
TABLE 721.2.2.1 "MINIMUM SLAB THICKNESS"  
ARCHITECT / CONTRACTOR MUST VERIFY  
PRIOR TO FABRICATION.

**ARCHITECT/CONTRACTOR NOTE:**  
ALL SUBASSEMBLY COMPONENTS TO BE  
PROVIDED IN 10'-0" OR 20'-0" STOCK LENGTHS  
UNLESS OTHERWISE NOTED. THE SPECIFIC  
SYSTEMS DICTATE THE LENGTHS PROVIDED.

Model	Nominal "JT"	Joint Opening "JT"				Total Movement	Mat. Code
		Seismic Min.	Thermal Min.	Thermal Max.	Seismic Max.		
LASBE-NBR-4-1-.375R	4"	1"	3.8125"	4.1875"	5"	4"	NB1315
LASBE-NBR-4-1-.375R w/ PF-2018F-SC-4-2	4"	1.75"	3.8125"	4.1875"	5"	3.25"	NB1315

Representative:	Customer:	Project:	Location:	Project Number:
-----------------	-----------	----------	-----------	-----------------

**MM SYSTEMS**  
50 MM WAY  
PENDERGRASS, GA. 30567  
PHONE: 706-824-7500  
800-241-3460  
FAX: 706-824-7501  
[www.mmsystemscorp.com](http://www.mmsystemscorp.com)  
For Spec-Data, Installation Guides, or movement requirements, contact MMSC

**RIGHTS OF DESIGN**  
All rights of design, detail, engineering and/or invention contained herein are the property of MM Systems Corporation and hereby reserved and are not to be reproduced or provided to any other party. MM Systems Corporation reserves the right to amend or withdraw any information contained herein without notice and will not be liable for any inaccuracy or ambiguity of said information.

**LASBE-NBR-4-1-.375R**  
Model:  
Drawn by: LMP  
Scale: NTS  
Issue Date: 09-22-14  
Drawing Number: **NB1315**  
SHT. . OF .