


IMPORTANT FABRICATION NOTE
 4'-12" MINIMUM FACE OF SLAB (AS SHOWN) REQUIRED FOR OPTIONAL FIRE RATING TO BE AVAILABLE IN ACCORDANCE TO BCTB TABLE 721.2.2.1 "MINIMUM SLAB THICKNESS" ANCHOR EJECT. CONTRACTOR MUST VERIFY PRIOR TO FABRICATION.

DISCREPANCY RESOLUTION
 FIREBARRIER (OPTIONAL) TO ACHIEVE RATING. 2-HOUR FIRE BARRIER MUST BE INSTALLED IN 2-HOUR RATED SLAB. MINIMUM 4'-12" FACE. BARRIERS MUST BE INSTALLED IN STRICT ACCORDANCE WITH TYPICAL FLOOR-FIRE BARRIER INSTALLATION INSTRUCTIONS PROVIDED IN THIS SUBMITTAL.
 *CONTACT FACTORY FOR OTHER STYLES OF FIRE BARRIER.

Model	Nominal "JT"	Joint Opening "JT"				Total Movement	Mat. Code
		Seismic Min.	Thermal Min.	Thermal Max.	Seismic Max.		
LASBE-24-12-HD	24"	2.5"	18"	30"	36"	33.5"	
LASBE-24-12-HD w/ PF-2248CF-SC-24-24	24"	5"	18"	30"	36"	31"	

USE WITH LASB-24-24-HD
 RATED FOR VEHICULAR TRAFFIC

Representative:	Customer:	Project:	Location:	Project Number:
 MM SYSTEMS 50 MM WAY PENDERGRASS, GA. 30567 PHONE: 706-824-7500 800-241-3460 FAX: 706-824-7501 www.mmsystemscorp.com		RIGHTS OF DESIGN All rights of design, detail, engineering and/or invention contained herein are the property of MM Systems Corporation and hereby reserved and are not to be reproduced or provided to any other party. MM Systems Corporation reserves the right to amend or withdraw any information contained herein without notice and will not be liable for any inaccuracy or ambiguity of said information.		
		LASBE-24-12-HD		
		Model:	Scale:	Drawing Number:
LMP	NTS			
SHT. . OF .	Issue Date:			
	07-30-12			

For Spec-Data, Installation Guides, or movement requirements, contact MMSC