



IMPORTANT LIFE SAFETY NOTE
 NOTE 2 BARRIERS REQUIRED.
 MINIMUM WALL DEPTH REQUIRED FOR RATING:
 11.125" FOR SINGLE SIDE INSTALLATION (SHOWN)
 16.125" FOR DUAL SIDE INSTALLATION
 ARCHITECT / CONTRACTOR MUST VERIFY PRIOR
 TO FABRICATION

IMPORTANT LIFE SAFETY PRODUCT NOTE
 PF-2018CW-SC-10-5 (OPTIONAL)
 TO ACHIEVE RATING, 2-HOUR FIRE BARRIER MUST
 BE INSTALLED IN 2-HOUR RATED WALL. BARRIERS
 MUST BE INSTALLED IN STRICT ACCORDANCE
 WITH TYPICAL WALL FIRE BARRIER INSTALLATION
 INSTRUCTIONS PROVIDED IN THIS SUBMITTAL.

| Model | Nominal "JT" | Joint Opening "JT" | | | | Total Movement | Mat. Code |
|-------------------|-----------------|--------------------|--------------|--------------|--------------|-------------------|--------------|
| | | Seismic Min. | Thermal Min. | Thermal Max. | Seismic Max. | | |
| CRS-10-5_STUD_WPF | 10" | 5" | 7.5" | 12.5" | 15" | 10" | SW2609 |

USE WITH CRSL-10-2.5

CLEAR ANODIZE IS STANDARD FINISH

Representative: _____ Customer: _____ Project: _____ Location: _____ Project Number: _____

MM SYSTEMS
 50 MM WAY
 PENDERGRASS, GA. 30567
 PHONE: 706-824-7500
 800-241-3460
 FAX: 706-824-7501
www.mmsystemscorp.com
 For Spec-Data, Installation Guides, or movement requirements, contact MMSC

RIGHTS OF DESIGN
 All rights of design, detail, engineering and/or invention contained herein are the property of MM Systems Corporation and hereby reserved and are not to be reproduced or provided to any other party. MM Systems Corporation reserves the right to amend or withdraw any information contained herein without notice and will not be liable for any inaccuracy or ambiguity of said information.

CRS-10-5_STUD_WPF
 Model:
 Drawn by: LMP
 Scale: NTS
 Issue Date: 04-26-12
 Drawing Number: **SW2609**
 SHT. . OF .